



UL Verification Services Inc.
7036 Snowdrift Road
Allentown, PA 18106
610-774-1300

Performance Test Report

Relevant Standards
ENERGY STAR® Luminaires v2.2
ANSI C82.77-2014, ANSI C82.2-2002, ENERGY STAR Start Time Test Method
ANSI/IEEE C62.41.1-2002, ANSI/IEEE C62.41.2-2002

Prepared For
Shenzhen Jing Xin Long Optoelectronics Technology Co LTD
401, Building B, Shan Yue Hua Science Park
No. 63 Xintang village, Longhua District
Shenzhen, 518110
China

Catalog Number
JXL-TZ06-T12W-UDH-3000K
Order Number
13362090
Test Number
13362090.02

Test Date

2020-06-16

Prepared By

A handwritten signature in black ink, appearing to read 'Cordaryl Cousar'.

Cordaryl Cousar, Technician

Approved By

A handwritten signature in black ink, appearing to read 'Shivani Vyas'.

Shivani Vyas, Project Coordinator

The results contained in this report pertain only to the tested sample.
This report shall not be reproduced, except in full, without written approval of Underwriters Laboratories.



UL Verification Services Inc.
 7036 Snowdrift Road
 Allentown, PA 18106
 610-774-1300

Description: formed white aluminum housing, frosted lens enclosure
 Lamp: White LED array
 Ballast/Driver: One unmarked driver
 Mounting: Surface – Ceiling

Sample



Electrical Values		Operating Frequency	Dimming Percentage
Test Temperature:	25.1 °C	N/A	N/A
Voltage:	120.1 VAC	Start Time	Noise
Current:	0.1022 A	112.4 ms	N/A
Power:	12.11 W	Transient Protection	
Power Factor:	0.987	N/A	
Frequency	60 Hz		
Current THD	15.5 %		

Start Time

